

CERTIFICATE


TÜV NORD CERT GmbH
herewith declares that

Zhejiang Sunoren Solar Technology Co., Ltd.
No. 9, Pidu Road,
Haining City, Zhejiang Province,
China

is authorized to provide the product mentioned below with the mark as illustrated:

Description of product (details see Annex 2):

PV Modules with 6" Poly-crystalline Silicon Solar Cells



Valid until: 2026-01-31

Tested according to: IEC / EN 61215-1:2016;
IEC / EN 61215-1-1:2016;
IEC 61215-2:2016 / EN 61215-2:2017 + AC:2017 + AC:2018;
IEC 61730-1:2016 / EN IEC 61730-1:2018 + AC:2018;
IEC 61730-2:2016 / EN IEC 61730-2:2018 + AC:2018.

Registered No.: 44 780 21 406749 - 016
Manufacturer: see Annex 1
Test Report No.: 492011582.001



Essen, 2021.02.01



Anlage 1 zum Zertifikat Nr.: / Annex 1 to Certificate No.: 44 780 21 406749 - 016

Seite / Page 1 von / of 1

Aktenzeichen: / File reference: PVP07036/20P-02

2021-02-01

Manufacturer:

Manufacturer: **Jiaxing Nengfa Electronic Technology Co., Ltd.**
No. 76, Fengxiang East Road, Wutong Street,
Tongxiang City, Zhejiang Province, China

Factory inspection report no.: 862010526.001

Remark:

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.

A handwritten signature in blue ink, appearing to read "Rogger K...".

TÜV NORD CERT GmbH
Certification Body
Consumer Products

Description of product(s):

Module types:	PV Modules with 6" Poly-crystalline Silicon Solar Cells 72 cells: XNxxxP-72V (xxx = 320-345, in increment of 5) 60 cells: XNxxxP-60V (xxx = 265-285, in increment of 5)
Maximum system voltage:	1500V
Fuse rating:	15A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I
Design load (positive / negative):	3600Pa / 1600Pa
Safety factors:	1.5
Fire safety class:	Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

Remark:

For detailed product information, please refer to CDF (Constructional Data Form) in Annex 1 of test report.



TÜV NORD CERT GmbH
Certification Body
Consumer Products